

Legend		
Description	Quantity	Unit
2" FD-1	5	Count
2" WCO	6	Count
3" FD-1	1	Count
3" VTR	3	Count
4" FD-1	2	Count
4" POC CONNECT TO EXISTING SANITARY LINE	2	Count
4" WCO	3	Count
BACKWASH PIT	1	Count
EEWSH-1	1	Count
EWC-1	1	Count
L-1	3	Count
SAN 2 R 3'	4	Count
SAN 2 R 5'	7	Count
SAN 3 R 3'	15	Count
SAN 4 R 3'	7	Count
SAN 4 R 4'	1	Count
SS-1	1	Count
SWIMSUIT DRYER	1	Count
V 2 R 8'	7	Count
V 2 R 12'	22	Count
V 3 R 5'	3	Count
WC-1	3	Count
WWB-1	1	Count

1 **WASTE AND VENT ISOMETRIC**
NO SCALE

APEX ESTIMATING
Sample set · Project, owner and consultant details removed · apexestimatingservices.com



Legend		
Description	Quantity	Unit
1-1/2" POC CONNECT TO EXISTING WATER LINE	1	Count
BV-1	3	Count
CW 1	15.37	ft
CW 1-1/2	109.84	ft
CW 1-1/2 R 12'	1	Count
CW 1 R 9'	4	Count
CW 1/2 R 8'	13	Count
CW 3/4	101.42	ft
CW 3/4 R 8'	3	Count
DCP-1	1	Count
G 1	1.54	ft
G 3/4	7.68	ft
GWH-1	1	Count
HB-1	3	Count
HW 1-1/2	68.27	ft
HW 1/2 R 8'	12	Count
HW 3/4	59.26	ft
HWR 3/4	115.64	ft
HWR 3/4 R 8'	3	Count
MV-1	2	Count
MV-2	1	Count
RPBFP-1	1	Count
RPBFP-2	1	Count

1 **PLUMBING DOMESTIC WATER AND GAS FLOOR PLAN**

SCALE: 1/4" = 1'-0"

SCALE: 1/4" = 1'-0"

APEX ESTIMATING
Sample set · Project, owner and consultant details removed · apexestimatingservices.com



GENERAL NOTES:

1. CONTRACTOR SHALL FIELD VERIFY ALL EXISTING UTILITY LOCATIONS, SIZES AND INVERT ELEVATIONS PRIOR TO PRICING AND CONSTRUCTION.
2. NEW UTILITY CONNECTIONS SHALL BE MADE PER BASE BUILDING STANDARDS.
3. PATCH AND REPAIR TO MATCH EXISTING AS REQUIRED.
4. TRENCH DRAIN TO BE INSTALLED PER MANUFACTURER AND CODE. PROVIDE ALL END CAPS, OUTLETS, CORNER ASSEMBLIES, ETC. AS REQUIRED FOR A COMPLETE TRENCH DRAIN SYSTEM. GRATE TYPE PER SPLASH ZONE STANDARDS.
5. ALL FLOOR DRAIN LOCATIONS TO BE APPROVED BY ARCHITECT FOR CONFORMANCE WITH FLOOR PITCH, ADA CLEARANCES, HEALTH DEPARTMENT REQUIREMENTS AND ACCESSIBILITY REQUIREMENTS PRIOR TO INSTALLATION.

Legend

Description	Quantity	Unit
SAN 2 UG	26.83	ft
SAN 3 UG	85.69	ft
SAN 4 UG	215.32	ft
TD-1	173.00	ft
V 2	208.01	ft
V 3	10.59	ft

1 **PLUMBING SANITARY WASTE AND VENT FLOOR PLAN**

SCALE: 1/4" = 1'-0"

0 2'-0" 4'-0" 8'-0"

SCALE: 1/4" = 1'-0"

APEX ESTIMATING
Sample set · Project, owner and consultant details removed · apexestimatingservices.com



GENERAL NOTES:

A. COORDINATE ROOF PENETRATIONS WITH THE ROOFING CONTRACTOR (IF REQUIRED). PROVIDE AND PAY FOR ANY REQUIRED ROOFING BY ROOFING CONTRACTOR.

B. REFER TO ARCHITECTURAL PLANS AND KITCHEN VENDOR DRAWINGS FOR DIMENSIONAL INFORMATION.

C. A FINAL REPORT FOR THE TESTING AND ADJUSTING OF ALL NEW SYSTEMS SHALL BE COMPLETED PRIOR TO FINAL APPROVAL BY THE FIELD INSPECTOR. THIS REPORT SHALL BE SIGNED BY THE INDIVIDUAL RESPONSIBLE FOR PERFORMING THESE SERVICES.

D. AN OPERATION & SYSTEMS MANUAL SHALL BE PROVIDED TO THE OWNER OR REPRESENTATIVE AND TO THE FIELD INSPECTOR AT THE TIME OF FINAL INSPECTION.

E. AN AIR FILTER WITH A MINIMUM EFFICIENCY REPORTING VALUE (MERV) OF 8 OR HIGHER SHALL BE INSTALLED IN THE MECHANICAL SYSTEM FOR OUTSIDE AND RETURN AIR PRIOR TO OCCUPANCY.

F. THE HVAC REFRIGERATION AND FIRE SUPPRESSION EQUIPMENT SHALL NOT CONTAIN CFC OR HALONS.

G. CONTRACTOR IS RESPONSIBLE FOR ANY DAMAGE TO THE BUILDING STRUCTURE OR BUILDING UTILITIES CAUSED AS RESULT OF THE CONTRACTOR'S WORK UNDER THIS CONTRACT. IT IS RECOMMENDED THAT MASONRY/CONCRETE FLOORS/WALLS BE X-RAYED PRIOR TO ANY PENETRATIONS.

H. PRIOR TO CONSTRUCTION THE CONTRACTOR SHALL VERIFY THE LOCATION OF ALL EXISTING MECHANICAL

K. ALL CONCEALED LOW PRESSURE (<2"WG) COOLING & HEATING DUCT 20" DIA. OR LESS SHALL BE UL 181 CLASS 1 FACTORY MADE FLEXIBLE ALUMINUM DUCT INSULATED WITH R-6 INSULATION AND SHEATHED WITH A VAPOR PROOF POLYETHYLENE SLEEVE.

L. ALL ROUND FLEXIBLE SUPPLY TAIL PIECES SHALL BE UL 181 CLASS I FACTORY MADE ACOUSTICAL FLEXIBLE DUCT WITH NYLON LINER AND INSULATED WITH R-8 INSULATION SHEATHED WITH A VAPOR PROOF METALIZED POLYESTER SLEEVE. THE MAXIMUM ALLOWABLE LENGTH OF THE FLEX DUCT SHALL BE 6'-0" AND MAY NOT BE USED AS AN ELBOW.

M. ALL EXPOSED LOW PRESSURE (< 2"WG) COOLING & HEATING 20" DIA. OR LESS SHALL BE FACTORY MADE GALVANIZED 4-PLY SPIRAL LOCK SEAM DUCT LINED WITH R-8 INSULATION.

N. ALL CONCEALED INTERIOR RECTANGULAR COOLING & HEATING DUCT SHALL BE GALVANIZED METAL WRAPPED WITH R-8 INSULATION IN ACCORDANCE WITH LOCAL CODE.

O. ALL EXPOSED INTERIOR AND EXTERIOR RECTANGULAR COOLING & HEATING DUCT SHALL BE GALVANIZED METAL LINED WITH R-8 DUCT LINER IN ACCORDANCE WITH LOCAL CODE.

P. ALL ROUND ENVIRONMENTAL EXHAUST AIR DUCT AND OUTSIDE AIR DUCT SHALL BE SMOOTH ROUND GALVANIZED PIPE INSTALLED IN ACCORDANCE WITH CHAPTER LOCAL CODE.

Q. ALL RECTANGULAR DUCTWORK SERVING TYPE I HOODS SHALL BE CONSTRUCTED OF 0.064 IN CARBON STEEL (16 GA) OR 0.043 STAINLESS STEEL (18 GA) WELDED FOR A LIQUID TIGHT SEAL IN ACCORDANCE WITH LOCAL CODE.

R. DUCTWORK SHALL BE CONSTRUCTED AND SUPPORTED IN ACCORDANCE WITH THE LATEST EDITION OF THE HVAC DUCT

Legend

Description	Quantity	Unit
FABRIC DUCT 10"	40.47	ft
FABRIC DUCT 14"	64.46	ft
FABRIC DUCT 16"	61.86	ft
FABRIC DUCT 20"	16.08	ft
RECTANGULAR 8X12	25.13	ft
RECTANGULAR 12X12	23.62	ft
ROUND DUCT 4"	1.89	ft
ROUND DUCT 6"	36.39	ft
ROUND DUCT 8"	16.89	ft
ROUND DUCT 10"	57.22	ft
ROUND DUCT 12"	31.55	ft
ROUND DUCT 14"	18.06	ft
ROUND DUCT 16"	39.31	ft
ROUND DUCT 20"	5.02	ft

DIFFUSER SCHEDULE

CFM	Supply Neck Ø	CFM	Return Neck Ø
0 - 125	6"	0 - 100	6"
126 - 250	8"	101 - 200	8"
251 - 350	10"	201 - 375	10"
351 - 550	12"	376 - 625	12"
551 - 700	14"	625 - 925	14"
701 - 850	16"	< 925	See Plans

FOR ANY RUN-OUT OVER 20' IN LENGTH, USE NEXT SIZE UP ON THIS SCHEDULE. DETERMINE LENGTH IN FIELD.

1 **MECHANICAL FLOOR PLAN**
SCALE: 1/4" = 1'-0"

0 2'-0" 4'-0" 8'-0"
SCALE: 1/4" = 1'-0"

N

APEX ESTIMATING
Sample set · Project, owner and consultant details removed · apexestimatingservices.com



GENERAL NOTES:

A. COORDINATE ROOF PENETRATIONS WITH THE ROOFING CONTRACTOR (IF REQUIRED). PROVIDE AND PAY FOR ANY REQUIRED ROOFING BY ROOFING CONTRACTOR.

B. REFER TO ARCHITECTURAL PLANS AND KITCHEN VENDOR DRAWINGS FOR DIMENSIONAL INFORMATION.

C. A FINAL REPORT FOR THE TESTING AND ADJUSTING OF ALL NEW SYSTEMS SHALL BE COMPLETED PRIOR TO FINAL APPROVAL BY THE FIELD INSPECTOR. THIS REPORT SHALL BE SIGNED BY THE INDIVIDUAL RESPONSIBLE FOR PERFORMING THESE SERVICES.

D. AN OPERATION & SYSTEMS MANUAL SHALL BE PROVIDED TO THE OWNER OR REPRESENTATIVE AND TO THE FIELD INSPECTOR AT THE TIME OF FINAL INSPECTION.

E. AN AIR FILTER WITH A MINIMUM EFFICIENCY REPORTING VALUE (MERV) OF 8 OR HIGHER SHALL BE INSTALLED IN THE MECHANICAL SYSTEM FOR OUTSIDE AND RETURN AIR PRIOR TO OCCUPANCY.

F. THE HVAC REFRIGERATION AND FIRE SUPPRESSION EQUIPMENT SHALL NOT CONTAIN CFC OR HALONS.

G. CONTRACTOR IS RESPONSIBLE FOR ANY DAMAGE TO THE BUILDING STRUCTURE OR BUILDING UTILITIES CAUSED AS RESULT OF THE CONTRACTOR'S WORK UNDER THIS CONTRACT. IT IS RECOMMENDED THAT MASONRY/CONCRETE FLOORS/WALLS BE X-RAYED PRIOR TO ANY PENETRATIONS.

H. PRIOR TO CONSTRUCTION THE CONTRACTOR SHALL VERIFY THE LOCATION OF ALL EXISTING MECHANICAL EQUIPMENT THAT SERVING THIS AND NEARBY ADJACENT SPACES AND IS TO REMAIN. CONTRACTOR SHALL VERIFY THE PROPOSED LOCATIONS OF NEW MECHANICAL EQUIPMENT AND DETERMINE IF ANY CONFLICTS (CLEARANCES, ETC) EXIST BETWEEN EXISTING EQUIPMENT AND NEWLY INSTALLED EQUIPMENT CONTRACTOR SHALL NOTIFY THE ENGINEER IF EQUIPMENT EQUIPMENT CANNOT BE SUBSTANTIALLY INSTALLED AND LOCATED AS INDICATED BY THESE DRAWINGS.

I. ALL DUCTWORK SHALL BE CONSTRUCTED IN ACCORDANCE WITH SMACNA-2006 OR UL 181 AND CONFORM TO THE REQUIREMENTS OF THE LOCAL CODE.

J. ALL SUPPLY AND RETURN AIR DUCTS IN UNCONDITIONED SPACES SHALL HAVE R-8 INSULATION.

K. ALL CONCEALED LOW PRESSURE (<2"WG) COOLING & HEATING DUCT 20" DIA. OR LESS SHALL BE UL 181 CLASS 1 FACTORY MADE FLEXIBLE ALUMINUM DUCT INSULATED WITH R-8 INSULATION AND SHEATHED WITH A VAPOR PROOF POLYETHYLENE SLEEVE.

L. ALL ROUND FLEXIBLE SUPPLY TAIL PIECES SHALL BE UL 181 CLASS I FACTORY MADE ACOUSTICAL FLEXIBLE DUCT WITH NYLON LINER AND INSULATED WITH R-8 INSULATION SHEATHED WITH A VAPOR PROOF METALIZED POLYESTER SLEEVE. THE MAXIMUM ALLOWABLE LENGTH OF THE FLEX DUCT SHALL BE 6'-0" AND MAY NOT BE USED AS AN ELBOW.

M. ALL EXPOSED LOW PRESSURE (< 2"WG) COOLING & HEATING 20" DIA. OR LESS SHALL BE FACTORY MADE GALVANIZED 4-PLY SPIRAL LOCK SEAM DUCT LINED WITH R 8 INSULATION.

N. ALL CONCEALED INTERIOR RECTANGULAR COOLING & HEATING DUCT SHALL BE GALVANIZED METAL WRAPPED WITH R-8 INSULATION IN ACCORDANCE WITH LOCAL CODE.

O. ALL EXPOSED INTERIOR AND EXTERIOR RECTANGULAR COOLING & HEATING DUCT SHALL BE GALVANIZED METAL LINED WITH R-8 DUCT LINER IN ACCORDANCE WITH LOCAL CODE.

P. ALL ROUND ENVIRONMENTAL EXHAUST AIR DUCT AND OUTSIDE AIR DUCT SHALL BE SMOOTH ROUND GALVANIZED PIPE INSTALLED IN ACCORDANCE WITH CHAPTER LOCAL CODE.

Q. ALL RECTANGULAR DUCTWORK SERVING TYPE I HOODS SHALL BE CONSTRUCTED OF 0.054 IN CARBON STEEL, (16 GA) OR 0.043 STAINLESS STEEL (18 GA) WELDED FOR A LIQUID TIGHT SEAL IN ACCORDANCE WITH LOCAL CODE.

R. DUCTWORK SHALL BE CONSTRUCTED AND SUPPORTED IN ACCORDANCE WITH THE LATEST EDITION OF THE HVAC DUCT CONSTRUCTION STANDARDS METAL AND FLEXIBLE BY THE SHEET METAL AND AIR CONDITIONING CONTRACTORS NATIONAL ASSOCIATION INC. (SMACNA).

S. NO EXPOSED FLEXIBLE DUCTS SHALL BE USED.

T. NO RETURN AIR REGISTERS SHALL BE LOCATED 6'-0" OF A SUPPLY AIR DIFFUSER THAT DIRECTS SUPPLY AIR IN THE DIRECTION OF THE RETURN AIR REGISTER.

U. ALL DUCT AND OTHER RELATED AIR DISTRIBUTION COMPONENT OPENINGS SHALL BE COVERED WITH TAPE, PLASTIC, OR SHEET METAL UNTIL THE FINAL STARTUP OF THE HEATING, COOLING, AND VENTILATING EQUIPMENT.

Legend

Description	Quantity	Unit
DOAS-1	1	Count
EF-3	1	Count
EF-4	1	Count
EF-5	1	Count
EF-6	1	Count
EF-7	1	Count
PEF-1	1	Count
PEF-2	1	Count
RTU-1	1	Count
RTU-2	1	Count

1. CONTRACTOR TO PROVIDE
N. TERMINATE WITH WEATHER
D TURN DOWN THE OPEN
W. INTAKE TO BE FURNISHED
RAIN CAP
DDL AND BIRD SCREEN, ALL
UMINUM OR TYPE 316
ED DAMPER TO BE
OPERATION AND SHALL FAIL
R UNIT SHUTDOWN.

2. USTS OR VENTS ON THE
T LESS THAN 10 FEET FROM
ES ON THE ROOF.

3. R INTAKE AND EXHAUST
OM WATER HEATER.
S PER MANUFACTURER'S
AROLINA BUILDING CODE.

4. TRACTOR TO INSTALL AS PER
ENDATION. REFER TO
MORE DETAILS. COORDINATE
TURAL ELEMENTS AND

FLUE VENT/INTAKE TO BE
FACTURER'S
PS 2018.

R INTAKE AND EXHAUST
OM MAU-1. CONTRACTOR TO
URER'S INSTRUCTION AND
CODE.

UCTS ON THE BUILDING
ITH INSULATION WRAP.

1 **MECHANICAL ROOF PLAN**
SCALE: 1/4" = 1'-0"

0 2'-0" 4'-0" 8'-0"
SCALE: 1/4" = 1'-0"

N

APEX ESTIMATING
Sample set · Project, owner and consultant details removed · apexestimatingservices.com



1 **ELECTRICAL LIGHTING PLAN**

SCALE: 1/4" = 1'-0"

GENERAL NOTES:

A. FIXTURE SUBSTITUTIONS MAY BE MADE WITH APPROVAL FROM BUILD TEAM. ALL SUBSTITUTIONS MUST BE SUBMITTED FOR APPROVAL.

B. ALL CONDUCTORS SIZING IS BASED ON COPPER ONLY.

C. UNLESS OTHERWISE SPECIFIED ALL CIRCUITS ARE TO BE RUN WITH (2)#12; (1)#12GND IN 3/4"C.

D. PROVIDE A GREEN INSULATED GROUND WIRE IN ALL RECEPTACLE AND EQUIPMENT BRANCH CIRCUITS.

E. WIRE ALL EMERGENCY FIXTURES TO THE UNSWITCHED LEG OF THE NEAREST LIGHTING CIRCUIT.

F. REFER TO HOMERUNS FOR ALL LIGHTING CIRCUITING INFORMATION.

G. AVERAGE 1 FC FOR EMERGENCY ILLUMINATION TO BE ACHIEVED NEAR POOL AREA.

H. EC SHALL COORDINATE WITH OWNER/MANUFACTURER/ VENDOR FOR THE EXACT REQUIREMENT OF THE OCCUPANCY SENSORS PROVIDED IN POOL AREA. PROVIDE POWER PACKS AS PER REQUIREMENT. BASE BID ACCORDINGLY.

I. CONTRACTOR IS ADVISED TO UPDATE THE EMERGENCY LIGHT FIXTURE LOCATIONS/QUANTITY PER SITE REQUIREMENTS UPON FINAL INSPECTION OR PER LOCAL AHJ REQUIREMENTS.

J. CHEMICAL STORAGE AND CORROSIVE ENVIRONMENT AREAS, AS DEFINED IN NEC 680.2, SHALL UTILIZE WIRING METHODS IN ACCORDANCE WITH NEC 680.14. ONLY RIGID METAL CONDUIT (RMC), INTERMEDIATE METAL CONDUIT (IMC), PVC, AND REINFORCED THERMOSETTING RESIN CONDUIT ARE PERMITTED FOR WIRING IN THESE AREAS.

Legend

Description	Quantity	Unit
15.8 In Circular Ring Pendant	5	Count
31.5 In Circular Ring Pendant	6	Count
A: 4 FT DIRECT / INDIRECT FIXTURE	14	Count
C: Wall Sconce	6	Count
D: High Bay Pendant	12	Count
Dimmer Switch	2	Count
Directional Exit Sign / Emergency Light Combo With Battery Back Up	2	Count
Exterior Remote Egress Light	2	Count
H: 4 Ft Vapor Tight Fixture	3	Count
H1: 2 Ft Vapor Tight Fixture	3	Count
I: 6 In Recessed Downlight	5	Count
J: 2x4 Recessed Troffer	1	Count
K: Track Lighting	1	Count
Occupancy Sensor	5	Count
Occupancy Sensor Switch	10	Count
Three-Way Dimmer Switch	2	Count
Three-Way Switch	10	Count
Wall / Ceiling Mounted Ext Sign With Emergency Lights With Battery Back Up & Remote Capability	3	Count
Wall / Ceiling Mounted Ext Sign With Emergency Lights With Battery Back Up NEMA 4X	2	Count
Wall Mounted Emergency Lights With Battery Back Up	6	Count
Wall Mounted Emergency Lights With Battery Back Up NEMA 4X	6	Count
Wall Mounted Occupancy Sensors	7	Count

APEX ESTIMA
Sample set · Project, owner
ces.com

POOL EQUIPMENT SCHEDULE

KEY	DESCRIPTION	VOLTS	PH	LOAD HP.KW.FLA	CONNECTION RECEPT	CONNECTION DISC	CONNECTION OTHER	MOCP	FEEDER	CIRCUIT	NOTES
A	FILTRATION PUMP	208	1	13.9 A FLA		20 A T/2P 30A/F		20 A/2P	3#12, 1#12G, 3/4"C	C-1,3	2
B	FILTRATION PUMP	208	1	13.9 A FLA		20 A T/2P 30A/F		20 A/2P	3#12, 1#12G, 3/4"C	C-5,7	2
C	WATER LEVEL CONTROLLER	120	1	0.5 A FLA			J-BOX	20 A/1P	3#12, 1#12G, 3/4"C	C-9	2
D	CHEMICAL CONTROLLER	120	1	5 A FLA			J-BOX	20 A/1P	2#12, 1#12G, 3/4"C	C-11	2
E	POOL HEATER	120	1	5 A FLA			J-BOX	15 A/1P	2#12, 1#12G, 3/4"C	C-13	2
F	CHLORINE CHEMICAL PUMP	120	1	1.7 A FLA	NEMA 5-15R			20 A/1P	2#12, 1#12G, 3/4"C	C-2	2,3
G	ACID METERING PUMP	120	1	1.7 A FLA	NEMA 5-15R			20 A/1P	2#12, 1#12G, 3/4"C	C-4	2,3
H	SECONDARY DISINFECTION SYSTEM	120	1	20 W			J-BOX	20 A/1P	2#12, 1#12G, 3/4"C	C-6	2
J	LED POOL LIGHTS	120	1	1000 W			SEE NOTE	20 A/1P	2#12, 1#12G, 3/4"C	C-8	1,2
K	AQUASTAT	120	1	1730 W			J-BOX	20 A/1P	2#12, 1#12G, 3/4"C	C-10	2

GENERAL NOTES:
A. PROVIDE ALL REQUIRED J-BOXES, OUTLETS, AND DISCONNECTS NECESSARY FOR A COMPLETE INSTALLATION.
B. DEVICE FACEPLATES ARE TO BE STAINLESS STEEL.
C. ALL EQUIPMENT SPECIFICATIONS IN THIS SCHEDULE ARE BASIS OF DESIGN ONLY. EC TO CONFIRM ALL EQUIPMENT SPECIFICATIONS, ELECTRICAL LOADS, AND ELECTRICAL CONNECTIONS WITH ARCHITECT, GENERAL CONTRACTOR, AND OWNER PRIOR TO ROUGH-IN.

SPECIFIC NOTES:
1. POOL LIGHTS BY POOL CONTRACTOR. EC TO INSTALL JUNCTION BOXES AT POOL LIGHT LOCATIONS FOR FINAL CONNECTION BY POOL CONTRACTOR. COORDINATE EXACT LOCATIONS WITH POOL PLANS.
2. ESTIMATED LOAD. VERIFY ACTUAL LOADS IN FIELD. IF LOADS EXCEED THOSE FOUND IN THIS TABLE, NOTIFY ENGINEER IMMEDIATELY FOR REVISED DRAWINGS.
3. MANUFACTURER RECOMMENDS GFCI PROTECTION OF OUTLET.

OWNER PROVIDED EQUIPMENT SCHEDULE

KEY	DESCRIPTION	VOLTS	PH	LOAD HP.KW.FLA	CONNECTION RECEPT	CONNECTION DISC	CONNECTION OTHER	MOCP	FEEDER	CIRCUIT	NOTES
13	(2) SWIMSUIT DRYERS SWIMSUIT DRYER CO	120	1	8.6 A	SEE NOTE 2			20 A	2#12, 1#12G, 3/4"C	SEE PLANS	1,2
14A	(4) BLOW DRYER CONAIR H-1129	120	1	1875 W	NEMA 5-20P			20 A	2#12, 1#12G, 3/4"C	SEE PLANS	3
15	DRINKING FOUNTAIN ELKAY EZSTL8WSLK	115	1	6 A FLA	NEMA 5-15P			15 A	2#12, 1#12G, 3/4"C	SEE PLANS	4
16	COFFEE MACHINE KEURIG K-3550	115	1	1560 W	NEMA 5-15P			15 A	2#12, 1#12G, 3/4"C	SEE PLANS	
17	BEVERAGE FRIDGE SUMMIT SCR314L	115	1	1.3 A FLA	NEMA 5-15P			15 A	2#12, 1#12G, 3/4"C	SEE PLANS	
19A	STACKING WASHER SAMSUNG SWF45B6300AW	120	1	15A	NEMA 5-15P			20 A	2#12, 1#12G, 3/4"C	SEE PLANS	
19B	STACKING DRYER SAMSUNG DVE45B6300W	240	1	30 A MCA	NEMA 6-30R			30 A	3#10, 1#10G, 3/4"C	SEE PLANS	
20	REFRIGERATOR HOTPOINT HPS10LGVRBB	115	1	6.0 A FLA	NEMA 5-15P			15 A	2#12, 1#12G, 3/4"C	SEE PLANS	
24	MICROWAVE GE JES1145DMBB	115	1	1580 W	NEMA 5-15P			15 A	2#12, 1#12G, 3/4"C	SEE PLANS	

GENERAL NOTES:
A. PROVIDE ALL REQUIRED J-BOXES, OUTLETS, AND DISCONNECTS REQUIRED FOR A COMPLETE INSTALLATION.
B. DEVICE FACEPLATES ARE TO BE STAINLESS STEEL.
C. **ALL EQUIPMENT SPECIFICATIONS IN THIS SCHEDULE ARE BASIS OF DESIGN ONLY.** EC TO CONFIRM ALL EQUIPMENT SPECIFICATIONS, ELECTRICAL LOADS, AND ELECTRICAL CONNECTIONS WITH ARCHITECT, GENERAL CONTRACTOR, AND OWNER PRIOR TO ROUGH-IN.

SPECIFIC NOTES:
1. EC TO CONFIRM EQUIPMENT LOCATIONS AND CONNECTION METHODS WITH OWNER PRIOR TO INSTALL.
2. EC TO CONFIRM ELECTRICAL LOAD AND CONNECTION METHOD IN FIELD. STANDARD INSTALLATION REQUIRES EITHER (a) (1) NEMA 5-15P WALL CONNECTION OR (b) (1) FUSED SPUR DIRECT WIRE CONNECTION. REFER TO MANUFACTURER'S INSTALLATION INSTRUCTIONS.
3. EC TO INSTALL (1) DEDICATED 5-20 RECEPTACLE FOR EACH BLOW DRYER.
4. INSTALL DUPLEX RECEPTACLE AT 22-15/16" O.C. PER INSTALLATION INSTRUCTIONS. COORDINATE EXACT LOCATION WITH PLUMBING CONTRACTOR.

LUMINAIRE SCHEDULE

TYPE	DESCRIPTION	MFR	MODEL	DIMMING	VOLTS	CCT	LUMENS	WATTS	EFFICACY	MOUNTING	NOTES
			UNIT								
A	4 FT DIRECT / INDIRECT FIXTURE	CORONET	LS4 UPDN-4-50-MED-MED-UNV-DB-W-AC 3.5-AVI.BWG-AVI.BWG-NA-NA-NA	0-10V	120	5000 K	5520	44	125	PENDANT	
C	WALL SCONCE	BRUCK	ECLIPSE 1-103055-AL/WH	ELV	120	3000 K	630	9.2	68	WALL	
D	HIGH BAY PENDANT	LITHONIA	JEBL-18L-50K-80CRI-WH	0-10V	120	5000 K	18000	136	132	PENDANT	
F	15.8 IN CIRCULAR RING PENDANT	ACCESS LIGHTING	52067LEDD-MWH/ACR		120	3000 K	1750	25	70	PENDANT	
G	31.5 IN CIRCULAR RING PENDANT	ACCESS LIGHTING	52069LEDD-MWH/ACR		120	3000 K	3570	42	85	PENDANT	
H	4 FT VAPOR TIGHT FIXTURE	SYLVANIA	VAPOR-1B-040-UNV-D-8-40-48-EC-GR-E	0-10V	120	4000 K	4500	40	112.5	SURFACE	
H1	2 FT VAPOR TIGHT FIXTURE	SYLVANIA	VAPOR-1A-025-UNV-D-8-40-24-EC-GR	0-10V	120	4000 K	2800	25	112	SURFACE	
I	6 IN RECESSED DOWNLIGHT	NORA	NFLIN-R610	ELV	120	3000 K	1450	16	91	RECESSED	
J	2X4 RECESSED TROFFER	ORACLE LIGHTING	24-ODVH-LED-6000L-DIM 10-MVOLT-50K-90-24FK	0-10V	120	5000 K	6256	50	125	RECESSED	
K	TRACK LIGHTING	LAMP PLUS PRO	DL-105A-WHITE TRACK LTS-WT		120	3000 K			#DIV/0!	SURFACE	
X1	WALL / CEILING MOUNTED EXIT SIGN WITH EMERGENCY LIGHTS WITH BATTERY BACK UP & REMOTE CAPABILITY	EXITRONIX	VLED-U-WH-EL90L-R	-	120	-	-	-	-	SURFACE	
X2	DIRECTIONAL EXIST SIGN / EMERGENCY LIGHT COMBO WITH BATTERY BACK UP	EXITRONIX	LCE-LB	-	120	-	-	-	-	SURFACE	
X3	WALL / CEILING MOUNTED EXIT SIGN WITH EMERGENCY LIGHTS WITH BATTERY BACK UP NEMA 4X	EXITRONIX	NXFC-1-R-12-28-WH	-	120	-	-	-	-	SURFACE	
Y1	WALL MOUNTED EMERGENCY LIGHTS WITH BATTERY BACK UP	EXITRONIX	LED-95-WH	-	120	-	-	-	-	SURFACE	
Y2	WALL MOUNTED EMERGENCY LIGHTS WITH BATTERY BACK UP NEMA 4X	EXITRONIX	NXFE-12-36-WH	-	120	-	-	-	-	SURFACE	
Y3	EXTERIOR REMOTE EGRESS LIGHT	EXITRONIX	RL52-WH-W-LO	-	120	-	-	-	-	SURFACE	

ABBREVIATIONS: BOF - BOTTOM OF FIXTURE, RFD - RECESSED FIXTURE DEPTH, OFH - OVERALL FIXTURE HEIGHT, AFF (AFG) - ABOVE FINISHED FLOOR (GRADE), WFD - WALL FIXTURE DEPTH

GENERAL NOTES:
1. PROVIDE LED LAMP WITH WATTAGE NO GREATER THAN LISTED WATTAGE IN LAMPING COLUMN.
2. ALL LAMPS SHALL BE LED TO COMPLY WITH CURRENT ENERGY CODE.
3. PROVIDE IC RATED FIXTURE IF REQUIRED AT MOUNTING LOCATION.
4. REFERENCE ARCHITECTUAL PLANS FOR EXACT MOUNTING HEIGHTS FOR ALL PENDANTS, SUSPENDED FIXTURES, POLE LUMINAIRES AND WALL SCONCES.
5. REFER TO ARCHITECT OR OWNER FOR FINISH.
6. COORDINATE EXACT DIMMING PROTOCOL WITH MANUFACTURER PRIOR TO BID AND PURCHASE.

Replaced Panel 'B'

Location: VACUUM / ELECT.
Supply From: STEP DOWN XFMR
Mounting: Surface
Enclosure: NEMA 1
Volts: 208
Phase: 3
Wires: 4
A.I.C. Rating: 22,000 AIC
Mains Type: Copper
Mains Rating: 200 A
MCB Rating: 200 A/3P

Panel notes:

CKT #	Load Description	Circuit Breaker Type	Load Class	Load VA	BUS	Load VA	Load Class	Circuit Breaker Type	Load Description	CKT #
1	E - DRYER (19B)	GFCI	[E]	2700	A	1080	[R]	GFCI	R - CHANGING RM RECEPT	2
3	/	GFCI	[E]	2700	B	1875	[R]	GFCI	R - HAIR DRYER (14A)	4
5	E - WASHER (19A)	GFCI	[E]	1800	C	1875	[R]	GFCI	R - HAIR DRYER (14A)	6
7	R - POOL RECEPTACLES	GFCI	[R]	720	A	1875	[R]	GFCI	R - HAIR DRYER (14A)	8
9	R - LOBBY RECEPTACLES		[R]	1260	B	1032	[E]	GFCI	E - SWIMSUIT DRYER (13)	10
11	R - SHOW WINDOW RECEPTACLES		[R]	360	C	500	[R]		R - LOBBY TV'S	12
13	R - RESTROOM RECEPTACLES	GFCI	[R]	360	A	720	[R]		R - OFFICE RECEPTACLES	14
15	E - EWC	GFCI	[E]	370	B	180	[R]	GFCI	R - COFFER BAR AC RECEPTACLE	16
17	R - RECEPTION RECEPTACLES		[R]	720	C	1560	[R]	GFCI	R - KEURIG MAKER	18
19	SPARE				A	180	[R]	GFCI	R - ROOF EQUIPMENT RECEPTACLE	20
21	R - RECEPTION BAR RECEPTACLES	GFCI	[R]	360	B	63	[R]	GFCI	E - DCP-1	22
23	E - UC REF	GFCI	[E]	156	C	620	[E]	GFCI	E - GWH-1	24
25	SPARE				A				SPARE	26
27	E - EF-6,7	GFCI	[E]	900	B	240	[E]	GFCI	E - EF-1,2,3,4,5	28
29	E - POOL EXHAUST PEF-1	GFCI	[E]	1068	C	1068	[E]	GFCI	E - POOL EXHAUST PEF-2	30
31	SPARE				A					32
33	SPARE				B	842	[L]		L - VIEWING / LOBBY LTS	34
35	L - POOL AREA LIGHTS	GFCI	[L]	1858	C	813	[L]	GFCI	L - CHANGING RM / RR / OFFICE LTS	36
37	SPACE				A	7733	[S]		PANEL C	38
39	SPACE				B	3480	[S]		/	40
41	SPACE				C	2090	[S]		/	42

CB Type legend: GFCI: 5mA ground fault circuit interrupter

Load Classification:	Connected Load	Demand Factor	Estimated Demand
[E] Equipment	12,634 VA	100%	12,634 VA
[R] Receptacle	5,940 VA	100%	5,940 VA
Receptacle over 10KVA	0 VA	50%	0 VA
[L] Lighting	3,413 VA	125%	4,266 VA
[LM] Largest Motor	0 VA	125%	0 VA
[M] Motor	0 VA	100%	0 VA
[KE] Kitchen Equipment	0 VA	100%	0 VA
[S] Subfeed Panels	13,303 VA	100%	13,303 VA
[EV] EV Chargers	0 VA	125%	0 VA
[A] Appliances	0 VA	100%	0 VA
Totals:	35,290 VA		36,143 VA

Panel Summary:		A	B	C	
Total Connected Load:	35.3 KVA	15,368	13,402	14,268	VA
Total Estimated Demand:	36.1 KVA	13,493	11,700	10,951	VA
Total Connected Amps:	98.0 A	128.0	111.6	118.8	A
Total Estimated Demand Amps:	100.3 A	112.4	87.4	91.2	A

Load Notes: Unused

Replaced Panel 'C'

Location: POOL EQUIPMENT
Supply From: STEP DOWN XFMR
Mounting: Surface
Enclosure: NEMA 4X
Volts: 208
Phase: 3
Wires: 4
A.I.C. Rating: 22,000 AIC
Mains Type: Copper
Mains Rating: 100 A
MCB Rating: MLO

Panel notes:

CKT #	Load Description	Circuit Breaker Type	Load Class	Load VA	BUS	Load VA	Load Class	Circuit Breaker Type	Load Description	CKT #
1	E - FILTERATION PUMP	GFCI	[E]	1660	A	1800	[E]	GFCI	E - POOL HEATER (GAS HEATER) (LO)	2
3	/	GFCI	[E]	1660	B	20	[E]	GFCI	E - CHLORINE CHEMICAL PUMP	4
5	E - FILTERATION PUMP	GFCI	[E]	1660	C	360	[R]	GFCI	R - EQUIPMENT ROOM RECEPTACLES	6
7	/	GFCI	[E]	1660	A	130	[L]	GFCI	L - EQUIPMENT ROOM LIGHTING	8
9	E - WATER LEVEL CONTROLLER	GFCI	[E]	50	B	20	[E]	GFCI	E - ACID METERING PUMP	10
11	/	GFCI	[E]	50	C	20	[E]	GFCI	E - SECONDARY DISINFECTION SYSTEM	12
13	E - CHEMICAL CONTROLLER (LO)	GFCI	[E]	1200	A	1000	[L]	GFCI	L - LED POOL LIGHTS	14
15	SPARE	GFCI			B	1730	[E]	GFCI	E - AQUASTAT	16
17	SPARE	GFCI			C			GFCI	SPARE	18
19	SPARE	GFCI			A				SPARE	20
21	SPARE				B				SPARE	22
23	SPARE				C				SPARE	24
25	SPARE				A				SPACE	26
27	SPACE				B				SPACE	28
29	SPACE				C				SPACE	30
31	SPACE				A				SPACE	32
33	SPACE				B				SPACE	34
35	SPACE				C				SPACE	36
37	SPACE				A				SPACE	38
39	SPACE				B				SPACE	40
41	SPACE				C				SPACE	42

CB Type legend: GFCI: 5mA ground fault circuit interrupter

Load Classification:	Connected Load	Demand Factor	Estimated Demand
[E] Equipment	11,530 VA	100%	11,530 VA
[R] Receptacle	360 VA	100%	360 VA
Receptacle over 10KVA	0 VA	50%	0 VA
[L] Lighting	1,130 VA	125%	1,413 VA
[LM] Largest Motor	0 VA	125%	0 VA
[M] Motor	0 VA	100%	0 VA
[KE] Kitchen Equipment	0 VA	100%	0 VA
[S] Subfeed Panels	0 VA	100%	0 VA
[EV] EV Chargers	0 VA	125%	0 VA
[A] Appliances	0 VA	100%	0 VA
Totals:	13,020 VA		13,303 VA

Panel Summary:		A	B	C	
Total Connected Load:	13.0 KVA	7,460	3,480	2,090	VA
Total Estimated Demand:	13.3 KVA	7,733	3,480	2,090	VA
Total Connected Amps:	36.1 A	62.0	29.0	17.4	A
Total Estimated Demand Amps:	36.9 A	64.4	29.0	17.4	A

Load Notes: Unused
(LO) - LOCKA

Legend

Description	Quantity	Unit
15A/1P	3	Count
20A/1P	36	Count
20A/1P	36	Count
20A/2P	6	Count
30A/2P	2	Count

APEX ESTIMATING
Sample set · Project, owner and consultant details removed · apexestimatingservices.com